



# CITY OF KERRVILLE LABORATORY

1000 THOMPSON DRIVE \* KERRVILLE, TEXAS 78028

TEL: (830) 257-4230 \* FAX :( 830) 257-4686

Email: Anna.Rachinsky@kerrvilletx.gov

## WATER ANALYSIS REPORT

### Customer Information:

Report ID: WP 06-03-24 JM

Name: Joseph McKiernan  
Address: Concan Water Supply  
Contact: 830-261-2111  
kmck@hctc.net

### Sample Information:

Sample ID	Date Received	Time Recd	Sampler Name	Collection Date	Collection Time	Sample Location
M0624-02	06-04-24	08:17	JM	06-03-24	14:05	House Pasture
M0624-03	06-04-24	08:17	JM	06-03-24	14:22	Well #6
M0624-04	06-04-24	08:17	JM	06-03-24	14:34	Utilities
M0624-05	06-04-24	08:17	JM	06-03-24	14:55	Well #4

### Test Results:

Sample Location	Analysis	Method	Result	Unit of Measure	Date Run	Analyst	Comments
House Pasture	Hardness, Total	SM 2340 C-1997	1133	mg/L	06-05-24	EF	66 grains per gallon
Well #6	Hardness, Total	SM 2340 C-1997	732	mg/L	06-05-24	EF	43 grains per gallon
Utilities	Hardness, Total	SM 2340 C-1997	693	mg/L	06-05-24	EF	41 grains per gallon
Well #4	Hardness, Total	SM 2340 C-1997	252	mg/L	06-05-24	EF	15 grains per gallon

### Comments:

*I included the grains per gallon in the comments area for water softener setting purposes.*

Further information on well water quality and drinking water standards can be found on the TCEQ and EPA websites:  
<http://www.tceq.state.tx.us/> and <http://water.epa.gov/drink/index.cfm>.

QA or Lab Manager: Samuel Bijott  
Date: 6.5.24